

Heckmann Building Products Inc.  
1501 N. 31st Avenue  
Melrose Park, IL 60160-2911  
800-621-4140 - 708-865-2403  
Fax: 708-865-2640  
[Heckmann@worldnet.att.net](mailto:Heckmann@worldnet.att.net)  
[www.heckmannbuildingprods.com](http://www.heckmannbuildingprods.com)

**WALLTIE SPECIFICATION**

SECTION 04085

MASONRY ANCHORS AND ACCESSORIES

PART 1 GENERAL

1.1 SECTION INCLUDES

\*\*\*\*\*  
NOTE: Delete items below not required for project.  
\*\*\*\*\*

- A. Masonry veneer anchors and ties.
- B. Stone veneer anchors and ties.
- C. Masonry accessories.

1.2 RELATED SECTIONS

- A. Section 04810 - Unit Masonry Assemblies.
- B. Section 04851 - Cut Stone Veneer.
- C. Section 04852 - Stone Masonry Veneer.

1.3 REFERENCES

\*\*\*\*\*  
NOTE: Delete references from the list below that are not actually  
required by the text of the edited section.  
\*\*\*\*\*

- A. ASCE/ACI 530.1 - Specifications for Masonry Structures;  
1995.
- B. ASTM A 153/A 153M - Standard Specification for Zinc  
Coating (Hot-Dip) on Iron and Steel Hardware; 1998.
- C. ASTM A 167 - Standard Specification for Stainless and  
Heat-Resisting Chromium-Nickel Steel Plate, Sheet, and  
Strip; 1996.
- D. ASTM A 240/A 240M - Standard Specification for Heat-

Resisting Chromium and Chromium-Nickel Stainless Steel Plate, Sheet, and Strip for Pressure Vessels; 1998b.

- E. ASTM A 276 - Standard Specification for Stainless Steel Bars and Shapes; 1998b.
- F. ASTM A 479/A 479M - Standard Specification for Stainless and Heat-Resisting Steel Bars and Shapes for Use in Boilers and Other Pressure Vessels; 1997a.
- G. ASTM A 580/A 580M - Standard Specification for Stainless Steel Wire; 1998.
- H. ASTM A 653/A 653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 1998.
- I. ASTM B 633 - Standard Specification for Electrodeposited Coatings of Zinc on Iron and Steel; (Reapproved 1994).

#### 1.4 SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. Product Data: Manufacturer's data on each type of product furnished.

### PART 2 PRODUCTS

#### 2.1 MANUFACTURERS

- A. Acceptable Manufacturer: Heckmann Building Products Inc., 1501 N. 31st Avenue Melrose Park, IL 60160-2911  
Tel: (708) 865-2403. Fax: (708) 865-2640  
Email: Heckmann@worldnet.att.net.  
Website: [www.heckmannbuildingprods.com](http://www.heckmannbuildingprods.com).

\*\*\*\*\*  
NOTE: Delete paragraph below; coordinate with Division 1 requirements.  
\*\*\*\*\*

- B. Requests for substitutions will be considered in accordance with provisions of Section 01600.
- C. Substitutions: Not permitted.

#### 2.2 APPLICATIONS

- A. Provide anchoring systems that comply with ACI 530.1/ASCE 6/TMS 602.

\*\*\*\*\*

NOTE:Delete the following items not needed for your project  
\*\*\*\*\*

B. Products.

1. **NO. 251 Z-WIRE WALL TIE**  
[3/16 inch (4.76 mm)][1/4 inch (6.35 mm)] diameter x  
[length] x 2 inch (51 mm) bends.
2. **NO. 253 RECTANGULAR WIRE WALL TIE**  
[3/16 inch (4.76 mm)][1/4 inch (6.35 mm)] diameter x  
[length] x [width].
3. **NO. 260 CORRUGATED WALL TIE**  
[gage] x [width] x [length]
4. **NO. 268 METAL LATH WALL TIE**  
[3.4 lb galvanized lath][2.5 painted lath] x [length]  
x width]
5. **NO. 269 WIRE MESH WALL TIE**  
2 x 2 (1/2 inch (12 mm)) 16 gage hotdip galvanized  
wire x [length] x [width]
6. **186 BRICK VENEER ANCHOR (NO HOLE)**  
[gage] x [width] x [length] x [bend length]
7. **187 HOLE-TYPE BRICK VENEER ANCHOR**  
[gage] x [width] x [length] x [bend length]
8. **188 SLOTTED TYPE BRICK VENEER ANCHOR**  
[gage] x [width] x [length] x [bend length]

2.3 MATERIALS

A. Steel Types

1. Stainless Steel: Type 304.
  - A. Sheet Metal: ASTM A 167 or ASTM A 240/A 240M.
  - B. Wire: ASTM A 580/A 580M.
  - C. Bars: ASTM A 479/A 479M, annealed and ground.
  - D. Plates, Bars, and Shapes: ASTM A 167 or ASTM A 276.
2. Hot-Dip Galvanized Steel: Hot-dip galvanized after  
fabrication in accordance with ASTM A 153/A 153M,  
Class B-2.
3. Mill Galvanized Steel:
  - A. Sheet Metal: ASTM A 653/A 653M, G60 coating.
  - B. Wire: ASTM A 641, regular coating; minimum 3/16 inch  
(4.76 mm) diameter.

PART 3 EXECUTION

3.1 INSTALLATION

- A. Install as specified in applicable masonry section(s) and  
in accordance with manufacturer's instructions.

END OF SECTION