

SECTION 04085

MASONRY ANCHORS AND ACCESSORIES

PART 1 GENERAL

1.1 SECTION INCLUDES

NOTE: Delete items below not required for project.

- A. Masonry veneer anchors and ties.
- B. Stone veneer anchors and ties.
- C. Masonry accessories.

1.2 RELATED SECTIONS

- A. Section 04810 - Unit Masonry Assemblies.
- B. Section 04851 - Cut Stone Veneer.
- C. Section 04852 - Stone Masonry Veneer.

1.3 REFERENCES

NOTE: Delete references from the list below that are not actually
required by the text of the edited section.

- A. ASCE/ACI 530.1 - Specifications for Masonry Structures;
1995.
- B. ASTM A 153/A 153M - Standard Specification for Zinc
Coating (Hot-Dip) on Iron and Steel Hardware; 1998.
- C. ASTM A 167 - Standard Specification for Stainless and
Heat-Resisting Chromium-Nickel Steel Plate, Sheet, and
Strip; 1996.
- D. ASTM A 240/A 240M - Standard Specification for Heat-
Resisting Chromium and Chromium-Nickel Stainless Steel
Plate, Sheet, and Strip for Pressure Vessels; 1998b.
- E. ASTM A 276 - Standard Specification for Stainless Steel
Bars and Shapes; 1998b.
- F. ASTM A 479/A 479M - Standard Specification for Stainless
and Heat-Resisting Steel Bars and Shapes for Use in
Boilers and Other Pressure Vessels; 1997a.
- G. ASTM A 580/A 580M - Standard Specification for Stainless
Steel Wire; 1998.

- H. ASTM A 653/A 653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 1998.
- I. ASTM B 633 - Standard Specification for Electrodeposited Coatings of Zinc on Iron and Steel; (Reapproved 1994).

1.4 SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. Product Data: Manufacturer's data on each type of product furnished.

PART 2 PRODUCTS

2.1 MANUFACTURERS

Acceptable Manufacturer: Heckmann Building Products Inc.,
1501 N. 31st Avenue, Melrose Park, IL 60160
800-621-4140 or 708-865-2403 FAX: 708-865-2640
Email: Heckmann@worldnet.att.net.
Website: www.heckmannbuildingprods.com.

NOTE: Delete paragraph below; coordinate with Division 1 requirements.

- A. Requests for substitutions will be considered in accordance with provisions of Section 01600.
- B. Substitutions: Not permitted.

2.2 APPLICATIONS

- A. Provide anchoring systems that comply with ACI 530.1/ASCE 6/TMS 602.

2.3 MATERIALS

A. Steel Types

- 1. Stainless Steel: Type 304.
 - A. Sheet Metal: ASTM A 167 or ASTM A 240/A 240M.
 - B. Wire: ASTM A 580/A 580M.
 - C. Bars: ASTM A 479/A 479M, annealed and ground.
 - D. Plates, Bars, and Shapes: ASTM A 167 or ASTM A 276.
- 2. Hot-Dip Galvanized Steel: Hot-dip galvanized after fabrication in accordance with ASTM A 153/A 153M, Class B-2.
- 3. Mill Galvanized Steel:
 - A. Sheet Metal: ASTM A 653/A 653M, G60 coating.

B. Wire: ASTM A 641, regular coating; minimum 3/16 inch (4.76 mm) diameter.

B. Products

1. **NO. 197 CORRUGATED-TYPE COLUMN & WALL ANCHOR**

1/8 inch (3.17 mm) x 1-1/4 inch (32 mm) x [length] with [length] of corrugation.

PART 3 EXECUTION

3.1 INSTALLATION

A. Install as specified in applicable masonry section(s).

END OF SECTION